



SUBMITTAL DATA: CM12				
Job Name:	Locatio	on:		Date:
Puchaser:	Engine	er:		
Submitted to:	For [Reference	☐ Approval	☐ Construction
Unit Designation:	Schedu	ıle No.:		

- 10,500 Btu/h at 80°F 50% RH (Evaporator) 95°F 50% RH (Condenser)
- 115V, 15 amps no special electric required
- No floor space needed
- Can fit into tight ceiling spaces

Technical Specs		CM12	
Electronic Features	Operation	Millivolt Thermostat	
	Control	(Not Included) Electronic	
Electrical Characteristics	Voltage Requirement	115V, 1 Phase, 60 Hz	
	Min. – Max. Voltage Recommended Fuse Size	105–125V 15 amps	
Cooling Capacity	Total Cooling Capacity	10,500 Btu/h ¹	
Evaporator: 80°F, 50% RH	Sensible Cooling Capacity	7,200 Btu/h ¹	
Condensor: 95°F, 50% RH	Power Consumption	1.23 kW ¹	
	Current Consumption	11.2 amps ¹	
Cooling Capacity	Total Cooling Capacity	9,200 Btu/h¹	
Evaporator: 72°F, 50% RH Condensor: 95°F, 50% RH	Sensible Cooling Capacity Power Consumption	6,900 Btu/h¹ 1.23 kW¹	
Condensor. 93 F, 30% Kn	Current Consumption	11 amps ¹	
Evaporator	Fan Type	Centrifugal	
	Max. Air Flow - high/low	324/228 CFM ¹	
	Max. External Static Pressure	0.16 IWG	
Condenser	Fan Type	Centrifugal	
	Max. Air Flow - high/low Max. External Static Pressure	700/370 CFM ¹	
	Max. External Static Pressure	0.12 IWG	
Compressor	Type Output	Hermetic Rotary 0.91 kW	
	·		
Refrigerant	R-410A*	1.23 lbs	
Dimensions (w/flange)	WxDxH	35 x 23 x 15.5 in	
Net Weight/Shipping Weight		128/141 lb	
Power Cord	Gauge/Length	N/A / N/A	
Condensate Pump		Auto Pump Included with a 4ft lift capacity	
Operating Conditions	Min. – Max. (@ 50% RH)	65°–95°F (Evaporator)	
		65°–113°F (Condenser)	
Max. Duct Length	Cold Duct Hose	20 ft ²	
	Hot Duct Hose	10 ft ²	
Max. Sound Level	Under Ceiling Tile with	52 dB(A)	
	Evaporator Duct	· <i>·</i>	

¹ Measured with two 6 ft ducts with one 90° bend each, supply grill and return grill with filter (0.16 IWG external static pressure) (ducts not included) 2 Confirm pressure drop of duct, grills and filter with manufacturer's specifications (ducts not included) * Check manufacturer or reseller for refrigerant type







