

Technical Instructions

Document No. 155-213 TB 167 Rev. 3, December, 2001

Powers[™] Controls

Restrictors





Type 1. 1/8" (3.2 mm) NPT Brass Threaded In-Line Restrictor. Typical 184-041

Description

Type 2. 1/4" (6.4 mm) O.D. Plastic Tube In-Line Restrictor. Typical 184-117 **Type 3.** 1/4" (6.4 mm) O.D. Plastic Tube Restrictor Tee. Typical 184-114

Powers restrictors are available in a variety of orifice sizes and connection types. External types 1, 2 and 3 feature:

- Air filter.
- Threaded connection (Type 1).
- Barbed connection (Types 2 and 3).
- Color coding (Types 2 and 3).
- Airflow direction arrow to minimize installation errors.
- Airflow restrictor capacity molded (Types 2 and 3) or stamped (Type 1) on body.

Restrictor installation kits and service repair kits are also available for Powers products that use plate or cartridge restrictors.


Product Numbers				
Type 1 In-Line Threaded (Package of 1)	Type 2 In-Line Barbed (Package of 5)	Type 3 Tee Barbed (Package of 5)	Barbed Restrictor Body Color	Normal Restrictor Flow Capacity scim (ml/sec)
184-039	184-115	184-112	Red	10 (2.7)
184-040	184-116	184-113	Yellow	20 (5.5)
184-041	184-117	184-114	Green	40 (11)
184-042	_		_	80 (22)
184-052	—	_	—	320 (87)

Table 2. Restrictor Flow Capacity At Various Air Pressure Drops.

Air Pressure	Percent of	Nominal Restrictor Flow Capacity				
Drop psi (kPa)	Maximum Flow Capacity	10 scim (ml/sec.)	20 scim (ml/sec.)	40 scim (ml/sec.)	80 scim (ml/sec.)	320 scim (ml/sec.)
22 (152)	100%	10 (2.7)	20 (5.5)	40 (11)	80 (22)	320 (87)
10 (69)	70%	7 (1.9)	14 (3.8)	28 (7.6)	56 (15)	224 (61)
5 (34)	50%	5 (1.4)	10 (2.7)	20 (5.5)	40 (11)	160 (44)
2.5 (17)	35%	3.5 (1.0)	7 (1.9)	14 (3.8)	28 (7.6)	112 (31)

Siemens Building Technologies, Inc.

Specifications	Material Type 1 Types 2 and 3	Brass Plastic	
	Ambient Temperature Minimum Maximum	40°F (4°C) 140°F (60°C)	
	Air Capacity	See Table 2	
	Air Connections Type 1 Types 2 and 3	1/8-inch (3 mm) NPT Thread Barb for 1/4-inch (6 mm) O.D. Polyethylene Tubing	
	Mounting	In-line	
Application	External restrictors are used:		
	• for one-pipe transmitters,	40 scim (11 ml/sec). See Figures 1 and 2.	
	 when installed tubing leng and 2. 	oths exceed maximum recommended value. See Figures 1	
	• for one-pipe room thermo	stats, 20 scim (5.5 ml/sec). See Figure 3.	
	 with check valves to prov 	ide airflow time delays.	
	 Slow to supply, fast to exhaust. See Figure 4. 		
	 Fast to supply, slow to exhaust. See Figure 5. 		
	 for VAV vortex control. Us pressure line to prevent c 	se 80 scim (22 ml/sec) restrictor in actuator control ycling.	
		10 scim (2.7 ml/sec), 80 scim (22 ml/sec) or 320 scim to compensate for tubing size or response time.	
T	ONE PIPE HERMOSTAT, TRANSMITTER DR CONTROLLER	ONE PIPE THERMOSTAT, TRANSMITTER OR CONTROLLER	
	B	A S S S S S S S S S S S S S S S S S S S	
	S ~ CONTROL	40 SCIM EXTERNAL RESTRICTOR TEE *	
INTERNAL 1	• • S C RC 195 2 3 RECEIVER- CONTROLLER	INTERNAL 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	
to exceed 1000 feet (30	eed 300 feet (91m). "A" + "B" not 5 m). If the transmitter is more m RC-195, use an external	* USE EXTERNAL RESTRICTOR WITH RC 195 WHEN "A" LENGTH EXCEEDS 300 FT. (91 m) OR WHEN "A+B" LENGTH EXCEEDS 1000 FT. (305 m).	
-	mitter/Receiver-Controller pplication.	Figure 2. Transmitter/Receiver-Controller Application.	






Figure 5. Time Delay Slow to Supply - Fast to Exhaust.

Figure 6. Time Delay - Fast to Supply - Slow to Exhaust.

Installation

Install external types 1, 2 and 3 restrictors so air flows in the direction indicated by the arrow. This ensures that only filtered air passes through restriction, reducing the possibility of clogging. Typical connections are shown in Figure 7.




Figure 7. Typical Connections.

Servicing

If an external type 1, 2, or 3 restrictor becomes clogged, it should be replaced. Do not attempt to replace the filter or clean the restrictor.

External Restrictors

TH182, TH192 Non Relay and **Free Energy Band**[™] TH193 HC (dual one-pipe) Thermostat External Restrictor Assembly. Kit 184-130.

The TH182 and TH192 non-relay (one-pipe) and **Free Energy Band** thermostats require external restrictors. The 184-130 restrictor kit is an assembly that permits easy installation of these thermostats. Kit 184-130 contains a supply air tee connected to two 20 scim (6 ml/sec) restrictor tees.

Internal Restrictors

TH180, TH182, TH188 Thermostat, HU 186 Hygrostat, and RL243 SS Relay Restrictor Replacement The kit number, airflow, and usage information is shown in Table 3. The restrictor plates are shown in Figure 8. To install, remove the two screws holding the restrictor cover plate and replace the two gaskets and restrictor.

Kit 180-893 contains ten each of the lower gasket, upper gasket, and restrictor plate so ten thermostats or hygrostats can be serviced.

Kit 188-159 contains ten lower gaskets, ten upper gaskets, five 20 scim (6 ml/sec) restrictor plates and five 40 scim (11 ml/sec) restrictor plates.


Restrictor KitAirflow with 20 psiProduct Number(138 kPa) DifferentialPressure scim (ml/sec)		Usage	
180-893	10 to 15 (3 to 4)	TH180 and TH182 Thermostats HU186 Hygrostats	
188-159	20 and 40 (6 and 11)	TH188 Thermostats RL243 SS Relay	

Table 3.	Airflow	and	Usage.
----------	---------	-----	--------

TH192 Thermostat and Hygrostat Restrictor Replacement. Kit 192-321.

Kit 192-321 contains restrictor plates, upper gaskets, and lower gaskets. Each kit contains the parts to repair ten thermostats or hygrostats.

- 1. Remove thermostat or hygrostat from wall.
- 2. Remove the two screws holding the connector.
- 3. Remove the old gaskets, filters and restrictor plate.
- 4. Reassemble new kit parts, placing them in the same relative positions as the original parts (See Figure 9).
- **NOTE:** The restrictor plate has a locating tab which fits in the space provided on the back of the unit.



RC 195 **Receiver-Controller** Restrictor Replacement. Kit 195-066.


The RC 195 Receiver-Controller restrictor replacement kit is 195-066. This kit contains three input restrictor assemblies, one supply restrictor assembly and seven gaskets. The restrictor assemblies are shown in Figure 10.

To replace Input Restrictor Assembly:

- Remove two holding screws and lift off restrictor cover. 1.
- 2. Remove and replace input restrictor assembly and two gaskets.
- 3. After replacing restrictor cover, tighten screws loosely so restrictor assembly can move.
- Move restrictor assembly up and down several times to align gaskets. 4.
- 5. Move lever into correct "In" or "Out" location.
- Tighten both screws together. Draw assembly up snuggly but do not over-tighten. 6.

To replace Supply Restrictor Assembly:

- 1. Remove two holding screws and lift off restrictor cover.
- Remove and replace supply restrictor assembly and gasket. 2.
- 3. After replacing restrictor cover, tighten screws together. Draw assembly up snuggly but do not over-tighten.



Input Restrictor Assembly Figure 10. RC 195 Restrictor.

Supply Restrictor Assembly

Dimensions




Figure 7. Dimensions in Inches (Millimeters).

Information in this publication is based on current specifications. The company reserves the right to make changes in specifications and models as design improvements are introduced. Powers and Free Energy Band are trademarks of Siemens Building Technologies, Inc. Other product or company names mentioned herein may be the trademarks of their respective owners. © 2001 Siemens Building Technologies, Inc.

Siemens Building Technologies, Inc. 1000 Deerfield Parkway Buffalo Grove, IL 60089-4513 U.S.A.

Your feedback is important to us. If you have comments about this document, please send them to technical.editor@sbt.siemens.com